

**UNHCR WASH STANDARDS and INDICATORS 2015**

	<b>Indicator</b>	<b>Emergency Standard</b>	<b>Post Emergency Standard</b>	<b>Means of Verification</b>
<b>Water Quantity</b>	Average # liters of potable water available per person per day	>15	>20	Monthly Report Card
	Average # L/p/d of potable water collected at HH level	>15	>20	Annual KAP
	% HHs with at least 10 liters/person potable water storage capacity	>70%	>90%	Annual KAP
<b>Water Access</b>	Maximum distance # (m) from HH to potable water collection point	>500m	>200m	Mapping Annual KAP
	# of persons per usable handpump/spring	<500	<250	Monthly Report Card
	# of persons per usable water tap	<250	<100	Monthly Report Card
<b>Water Quality</b>	% HHs collecting drinking water from potable sources	>70%	100%	Annual KAP
	% water quality tests at non chlorinated water collection locations with 0 FC/100ml	>70%	100%	Monthly Report Card
	% of water quality tests at chlorinated collection locations with FRC in the range 0.5-1mg/L and turbidity <5NTU	>70%	>90%	Monthly Report Card
<b>Sanitation</b>	# persons per latrine/toilet	<50	<10	Monthly Report Card
	% HHs with household or shared-family latrine/toilet	-	>90%	Annual KAP / MRC
	# persons per bath shelter / shower	<50	<20	Monthly Report Card
	% HHs reporting open defecation	0%	0%	Annual KAP
<b>Hygiene Promotion</b>	# persons per hygiene promoter	500	500	Monthly Report Card
	% HHs with access to soap and specific device for hand-washing	>70%	>90%	Annual KAP
<b>Solid Waste</b>	% HH with access to solid waste disposal facility	>70%	>90%	Annual KAP
<b>UNHCR WASH Standards for Communal Buildings</b>				
<b>Schools</b>	Average 3 liters of potable water available per pupil per day 400 of pupils per usable handpump/well 200 pupils per usable water tap 50 pupils per latrine/toilet (30 girls per toilet, 60 boys per toilet – add urinals for boys)			
<b>Health Clinics</b>	Average 10 liters of potable water available per outpatient per day Average 50 liters of potable water available per inpatient/bed per day 1 separated water point per health facility 20 outpatients per latrine/toilet 10 inpatients/beds per latrine/toilet			