

UNHCR GREECE Invitation to Bid ITB/GRC/2016-009

Renovation Civil Works for UNHCR Office in Lesbos

UPDATED CLARIFICATIONS

4/6/2016

1. The gypsum board must be fire proof. Exist the same for the internal glass window on the gypsum board?

Yes.

2. The security doors are 2 or 3 (2 in the entrance and one in the back)

There are 2 security doors. (in the entrance is a double door 1,60x2,20m and in the back 1.05x2,20m)

3. The window replacing will be only for the glasses or the hole window (frames and glasses)

Please refer to the amended BoQ document. This point has been erased.

4. We need technical specs for the two heat pumps of the ground floor and if there is a need for inside units (for example fun coils)

Please refer to the amended BoQ document. This point has been erased.

5. Potential exist for advance payment? (meant for a percentage)

Please refer to the ITB document paragraph 2.9 and also at Annex D (point 30, page 13).

6. The roofs of Meeting 1 and Meeting 2 have to be constructed with gypsum boards. That will be about (30 + 26) m2 single gypsum board or double with rock wool insulation?

The vertical gypsum boards for meeting room 1 and 2 will go up to the ceiling in the height of 4m.