

WASH UPDATE

As of 21 October 2011

Sanitation

Site	Population size	Total number of blocs	Total number of holes	Ratio Per user		STANDARD I (50P/HOLE)		STANDARD II (20p/HOLE)		Hygiene promoters		
				Emergency Standard (p/hole)	Actual (p/hole)	Additional required NOW to meet standard	Coverage in % currently	Additional required NOW to meet standard II	Coverage in % currently	Needed	Actual	To be added
Reception	400	3	30	50	13	0	375%	0	150%	1		1
Transit	4,429	10	80	50	55	9	90%	0	36%	8.858	2	0
Kobe	25,687	400	657	50	39	0	128%	627	51%	51	28	23
Melkadida	40,103	71	71	50	565	731	9%	1934	4%	80	62	18
Bokolmayo	37,708	310	454	50	83	300	60%	1431	24%	75	62	13
Helowin	24,816	48	192	50	129	304	39%	1049	15%	50		50
Total	132,743		1,292	50	103	1,363	49%	3,993	19%	265	154	106

Water Supply

Specific Site	Population size	Total volume of water provided (m3/d)	Ratio Per user		Total Volume of water needed to meet std	Number of distribution points	Coverage in terms of water points	Number of taps		Additional Taps required	Additional water points (6 taps)
			Standard (l/p/d)	Actual (l/p/d)				Req'd	Actual number		
Reception	400	10	15	25.0	0	1	375%	2	6	0	0
Transit	4,429	54	15	12.2	0	5	169%	18	30	0	0
Kobe Camp	25,687	350	15	13.6	35	25	146%	103	150	0	0
Melkadida	40,103	420	15	10.5	182	29	108%	160	174	0	0
Bokolmayo	37,708	370	15	9.8	196	20	80%	151	120	31	5
Hallawen	24,816	250	15	10.1	122	16	97%	99	96	3	1
Total	132,743	1,454		10.95	534.71	96	108%	532.972	576	34.096	6